



GABION STRUCTURE PLAN VIEW
SCALE 1:100

GENERAL NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED
2. THESE DRAWINGS MUST BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS BEFORE CONSTRUCTION COMMENCES
3. ALL DIMENSIONS MUST BE CHECKED AND ANY DISCREPANCIES MUST BE REFERRED TO THE ENGINEER FOR ATTENTION. DRAWINGS SHOULD NOT BE SCALED.
4. ALL DIMENSIONS AND LEVELS MUST BE CHECKED AND CONFIRMED ON SITE.
5. ALL FLOORS HAVE 1 TO 200 FALLS TO SUMPS LAID IN SCREED OF MINIMUM THICKNESS 50MM.
6. ALL CONCRETE TO BE CLASS 25/19 MPA UNLESS OTHERWISE STATED.
7. MINIMUM COVER TO REINFORCEMENT TO BE 40MM.
8. ALL FITTINGS TO BE PN16.

Rev	Date	Description	Approved

WATER AND SEWERAGE COMPANY (PTY) LTD
MASERU 100
LESOTHO

PROJECT: SEMONKONG GABION PLAN